

Danish Technological Institute	Pipe Centre	Page 1 of 11
Project number: 757848	Test conducted	d: May 2017

# Testing of door seal, type RAXIT® against rats

**Testing report** 

Project number: 757848

Performed for:

Producer: BarrierSteel IVS Kongevejen 345 A 2840 Holte Denmark

Keywords: Door seal, testing, rats

#### Testing made by:

Danish Technological Institute, Pipe Centre Gregersensvej 2630 Taastrup Denmark v/ Stig Clausen

Number of pages: 11 Number of appendices: 3

Taastrup, June 27th 2017



Danish Technological Institute	Pipe Centre	Page 2 of 11
Project number: 757848	Test conducted	d: May 2017

DANISH TECHNOLOGICAL INSTITUTE

# 1. Testing

#### 1.1. Test pieces

The 3 tested RAXIT® door seals were characterized by the following:

- They were opaque black
- They were 3 mm thick and 75 mm broad
- The length of the 3 door seals were:
  - 860 mm (horizontally mounted on active door panel)
  - 855 mm (horizontally mounted on passive door panel)
  - 500 mm (vertically mounted on active door panel)
- They were made of SantopreneTM 201-73 and 1 mm steel wires.
   The datasheets are attached as appendix 1
- They had been produced by simultaneous extrusion of the SantopreneTM. The steel wires were, therefore, completely encapsulated by the SantopreneTM – except in the end pieces, where the cross section of the wires could be seen
- There were 10 steel wires in each door seal
- The distance between each steel wire and the neighboring steel wire was 5 mm
- There were 3 mm from one of the edges to the nearest steel wire
- From the other edge there were 17 mm to the nearest steel wire

#### 1.2. Purpose and scope of the test

The test purpose was to test the door seal against rats.

The 3 RAXIT® door seals were tested on an old used double swing door of steel with each door panel mounted on 2 hinges. The door panels were 85 cm broad.

The astragal gab i.e. the distance between the 2 doors panels when closed was 8 mm.

The double door was mounted without any threshold. Under the double door there was mounted a 45 mm broad and 1% mm high steel strip. The purpose of the steel strip was to make the test setup reflect the way double doors in real life are mounted in Denmark in order to comply with Danish fire regulations (BD 60/EI $_2$  60-C). There was nothing between A) the bottom of the 2 door panels when closed and B) the underlying 1% mm high steel strip.

The threshold gab i.e. the distance between the bottom of the 2 door panels when closed and the underlying steel strip was 45 mm.

#### 1.3. Test implementation

The test was carried out at the Pipe Centre, Danish Technological Institute, Taastrup, Denmark from the 10<sup>th</sup> to 24<sup>th</sup> of May 2017.

The rat test has been according to the Danish test standard for rats in sewer systems with some adjustments where 2 rats has been in the system for 14 days with the product/sample. The first 7 days without the door seal (50 mm gap



Danish Technological Institute	Pipe Centre	Page 3 of 11
Project number: 757848	Test conducted	l: May 2017



between door and floor of the test box) and the following 7 days with the door seal. There is a drawing of the test set up and textbox in appendix 2.

The bottom of the quadrangular test box, where the double door was mounted and the test was performed, was 1.8 meter by 1.5 meter. The test box was 0.6 meter high.

The bottom and the walls of the test box were made of 18 mm brown HUSKYFORM F/F plate. On top of the test box there was a plywood plate with 2 transparent Plexiglas windows, which made it possible to observe the rats without taking the top plate of.

Attached to one end of the test box there was a small steel cage where the 2 rats could sleep. Attached to the opposite end of the box there was another small steel cage, where their food was served during the first week of the two week test period.

#### 1.4. Results

The results of the tests were as follows:

Product	Rat-test
Samples – door seal, type RAXIT® with metal wire (1 mm)	OK, bite marks from rats in the Santoprene but the rats has not passed the door seal

In appendix 3 there are shown pictures from the test.

#### 1.5. Conclusion

The RAXIT® door seal passed the test as the test criteria was satisfied.

The conclusion of the tests of the product is that no rats has passed the door seal from BarrierSteel, type RAXIT®, but there were bite marks in the Santoprene from the rats after 14 days of testing.

Danish Technological Institute, Pipe Centre

June the 8th 2017

Stig Clausen

Consultant

Ulrik Hindsberger

Mink Hindsberg


Centre Manager



INSTITUTE

Danish Technological Institute	Pipe Centre	Page 4 of 11	
Project number: 757848	Test conducted	d: May 2017	

#### Appendix 1: Datasheets with material of the door seal






Danish Technological Institute	Pipe Centre	Page 5 of 11
Project number: 757848	Test conducted	d: May 2017

DANISH TECHNOLOGICAL INSTITUTE

#### Appendix 1: Datasheets with material of the door seal





Danish Technological Institute	Pipe Centre	Page 6 of 11
Project number: 757848	Test conducted	d: May 2017

#### Appendix 1: Datasheets with material of the door seal

Product Datasheet



# Santoprene™ 201-73 Thermoplastic Vulcanizate

#### Product Description

A soft, colorable, versatile thermoplastic vulcanizate (TPV) in the thermoplastic elastomer (TPE) family. This material combines good physical properties and chemical resistance for use in a wide range of applications. This grade of Santoprene TPV is shear-dependent and can be processed on conventional thermoplastics equipment for injection molding, extrusion, blow molding, thermoforming or vacuum forming. It is polyolefin based and recyclable within the manufacturing stream.

#### Key Features

- UL listed: file #QMFZ2.E80017, Plastics Component; file #QMFZ8.E80017, Plastics Certified For Canada - Component.
- Although not NSF certified, this product has a Material Supplier Form on file with NSF to facilitate its evaluation for use in applications requiring NSF certification.
- Recommended for applications requiring excellent flex fatigue resistance.
- Excellent ozone resistance.

General				
Availability 1	<ul> <li>Africa &amp; Middle East</li> <li>Asía Pacific</li> </ul>	Europe     Latin America	• Non	th America
Applications	<ul> <li>Automotive - Plugs, Bumpers, Grommets, Clips</li> <li>Automotive - Seals and Gasket</li> </ul>	<ul> <li>Soft Touch Grips</li> </ul>	ets • Tubi	ng
Uses	<ul> <li>Appliance Components</li> <li>Automotive Applications</li> <li>Automotive Under the Hood</li> </ul>	<ul><li>Consumer Applications</li><li>Diaphragms</li><li>Electrical Parts</li></ul>	Gast Seal Tubi	5
Agency Ratings	• UL QMFZ2	• UL QMFZ8		-
RoHS Compliance	- RoHS Compliant			
Automotive Specifications	- CHRYSLER MS-AR-100 CGN	<ul> <li>FORD WSD-M2D380-A1</li> </ul>	. GM	SMP.E/P.003
UL File Number	- E80017		0	UNI 1.07 1.005
Color	Natural Color			
Form(s)	Pellets			
Processing Method	Blow Molding     Coextrusion     Extrusion     Extrusion Blow Molding	Injection Blow Molding     Injection Molding     Multi Injection Molding     Profile Extrusion	• Then	t Extrusion moforming um Forming
Revision Date	• 10/08/2014		-	
Physical	Typical Value (English)	Typical Value	(SI)	Test Based On
Specific Gravity	0.970	0.970	100	ASTM D792
Density	0.970 g/cm <sup>3</sup>	0.970	g/cm³	ISO 1183
Detergent Resistance	ß	f3		UL 749
Detergent Resistance	f4	f4		UL 2157
fardness	Typical Value (English)	Typical Value	(SI)	Test Based On
Shore Hardness				ISO 868
Shore A, 15 sec, 73°F (23°C)	78	78		



Danish Technological Institute	Pipe Centre	Page 7 of 11	
Project number: 757848	Test conducted	l: May 2017	

DANISH TECHNOLOGICAL INSTITUTE


#### Appendix 1: Datasheets with material of the door seal

Search	Result: (1 Pro	duct)				Property Set	: OASTIM ® ISO	Units:	● SI ○ Englis
Action	Grade Name	Medium	Temp.	Time (hr)	Change In Hardness (ISO)	Change in Mass (ISO) (%)	Change in Tensile Strength (ISO) (%)	Change in Ultimate Elongation (ISO) (%)	Change in Volume (ISO) (%)
	Santoprene™ 201-73	IRM 903 OII	126	70.0	青金金会 No Data Available	会会会会 No Data Available	*** -31	***** -47	**** 72
0 2	Santoprene™ 201-73	Sorium Hydroxide, 50%	23.0	188	***	***	****	****	東京東京 No Data Available
0 🖼	Santoprene <sup>78</sup> 201-73	Sodium Chloride, 15%	23.0	166	***	***	****	****	A A A A No Data Available
0	Santoprene <sup>78</sup> 201-73	Cyclohecane	23.0	168	***	****	***	***	素素素 No Data Available
	Santoprene™ 201-73	Detergent (Tide), 2.5%	23.0	168	***	***	***	***	未未未 No Data Available
	Santoprene <sup>16</sup> 201-73	Trichloroethylene	23.0	168	***	***	<b>★★</b> ※★ 54	***	*** No Data Available
0 🖂	Santoprene™ 201-73	IRM 903 Oil	125	166	*** -23	<b>★</b> 去古士 78	*** -31	**** *58	*** No Data Available
	Santoprene <sup>19</sup> 201-73	Ethanol, 95%	23.0	168	****	***	**** -2.0	***	東東東東 No Deta Available
0 🖾	Santoprene <sup>76</sup> 201-73	Acetic Adid	23.0	168	***	****	****	****	*** No Data Available
	Santoprene <sup>TH</sup> 201-73	Delanized Water	100	168	***	****	****	****	東京本章 No Data Available
0 🖂	Santoprene <sup>78</sup> 201-73	Isopropyl Alcohol	23.0	168	***	**** -13	*** 31	*** 20	*** No Data Available
	Santoprene <sup>78</sup> 201-73	Sulfuric Acid, 98%.	23.0	168	****	**** No Data Available	永永永 No Data Avallable	***± -27	Available
	Santoprene™ 201-73	Hydrochloric Acid, 10%	23.0	168	****	***	***	****	*** No Data Available
	Santoprene <sup>16</sup> 201-73	Methylethylketone	23.0	188	****	****	***** 47	****	東京東京 No Data Avaliable
Chinal I	Santoprene <sup>TIII</sup>	IRM 903 Oil	100	168	*** -21	**** 68	*** -30	<b>未</b> ★	★★★★ No Data Available



Danish Technological Institute	Pipe Centre	Page 8 of 11
Project number: 757848	Test conducted	d: May 2017

Appendix 2: Drawing of the test set up /test box





Danish Technological Institute	Pipe Centre	Page 9 of 11
Project number: 757848	Test conducted	d: May 2017







The testing is only valid for the tested specimen. The test report may only be extracted, if the laboratory has approved the extract.



Danish Technological Institute Pipe Centre Page 10 of 11
Project number: 757848 Test conducted: May 2017

DANISH TECHNOLOGICAL INSTITUTE

### Appendix 3: Photos from the test/test box (continued)





The testing is only valid for the tested specimen. The test report may only be extracted, if the laboratory has approved the extract.



DANISH TECHNOLOGICAL INSTITUTE

## Appendix 3: Photos from the test/test box (continued)



